

# FORM FOR PROPOSAL FOR 2014 NATIONAL ELECTRICAL CODE®

## INSTRUCTIONS — PLEASE READ CAREFULLY

Type or print **legibly** in **black ink**. Use a separate copy for each proposal. Limit each proposal to a **SINGLE** section. All proposals **must be received by NFPA by 5 p.m., EST, Friday, November 4, 2011**, to be considered for the 2014 National Electrical Code. Proposals received after 5:00 p.m., EST, Friday, November 4, 2011, will be returned to the submitter. If supplementary material (photographs, diagrams, reports, etc.) is included, you may be required to submit sufficient copies for all members and alternates of the technical committee.

**For technical assistance, please call NFPA at 1-800-344-3555.**

## FOR OFFICE USE ONLY

Log #: \_\_\_\_\_

Date Rec'd: \_\_\_\_\_

Please indicate in which format you wish to receive your ROP/ROC ☒ electronic ☐ paper ☐ download  
(Note: If choosing the download option, you must view the ROP/ROC from our website; no copy will be sent to you.)

Date 2 Nov 2011 Name John C. Wiles, Jr Tel. No. 575-646-6105  
Company Southwest Technology Development Institute, New Mexico State University Email jwiles@nmsu.edu  
Street Address 3705 RESEARCH DR/MSC 3 SOL City LAS CRUCES State NM Zip 88003

\*\*\*If you wish to receive a hard copy, a street address **MUST** be provided. Deliveries cannot be made to PO boxes.

Please indicate organization represented (if any) PV INDUSTRY FORUM

1. Section/Paragraph 705.60(B)

2. Proposal Recommends (check one): ☒ new text ☐ revised text ☐ deleted text

3. Proposal (include proposed new or revised wording, or identification of wording to be deleted): [Note: Proposed text should be in legislative format; i.e., use underscore to denote wording to be inserted (inserted wording) and strike-through to denote wording to be deleted (~~deleted wording~~).]

Add the following Informational Note after 705.60(B)

Informational Note: The ac output circuit of utility-interactive inverters and AC PV modules from the inverter to the first overcurrent device on that circuit is similar to a branch circuit. The circuit is sized at 125 percent of the continuous currents it carries. The circuit is protected from overloads and faults sourced from the utility by that overcurrent device that is typically located at the utility supply end of the circuit. The circuit responds in the same way when the overcurrent device activates—it becomes de-energized as the utility supply is removed and the inverter shuts down through actions of the internal anti-islanding system.

4. Statement of Problem and Substantiation for Proposal: (Note: State the problem that would be resolved by your recommendation; give the specific reason for your Proposal, including copies of tests, research papers, fire experience, etc. If more than 200 words, it may be abstracted for publication.)

The Informational Note is added to provide useful, factual information that will clarify how these circuits may be treated in the Code. UL Standard 1741 requires the anti-islanding function in all utility-interactive inverters and AC PV modules.

## 5. Copyright Assignment

(a) ☒ I am the author of the text or other material (such as illustrations, graphs) proposed in the Proposal.

(b) ☐ Some or all of the text or other material proposed in this Proposal was not authored by me. Its source is as follows: (please identify which material and provide complete information on its source)

I hereby grant and assign to the NFPA all and full rights in copyright in this Proposal and understand that I acquire no rights in any publication of NFPA in which this Proposal in this or another similar or analogous form is used. Except to the extent that I do not have authority to make an assignment in

*materials that I have identified in (b) above, I hereby warrant that I am the author of this Proposal and that I have full power and authority to enter into this assignment.*

**Signature (Required)**

*John L. Wiles Jr.*

---

**PLEASE USE SEPARATE FORM FOR EACH PROPOSAL**

Mail to: Secretary, Standards Council · National Fire Protection Association  
1 Batterymarch Park · Quincy, MA 02169-7471 OR  
Fax to: (617) 770-3500 OR Email to: [proposals\\_comments@nfpa.org](mailto:proposals_comments@nfpa.org) 8/5/2010